

Service

How to Adjust an Open Showcase for Berries & Produce (R290 Refrigerant)

1. Access the temperature controller located behind the louvered kickboard of the showcase. The louvered panel can be removed without using tools by simply lifting upward and pulling forward.
2. For a Carel brand controller,
 - a. Press the SET button to see the current setpoint value.
 - b. To adjust the setpoint value hold the SET button for more than 1 second. The value will be displayed flashing. Use the arrows to adjust the value, then press the SET button again to lock in the new value.



3. For a Dixell brand controller,
 - a. Press the SET button to see the current setpoint value.
 - b. To change the setpoint value hold the SET button for more than 2 seconds. The setpoint value will be displayed and the temperature unit indicator will begin flashing. Use the arrows to adjust the value, then press the SET button again to lock in the new value.



Note:

Any changes to the setpoint will require monitoring for several days afterwards to ensure that product temperatures are in the desired range. It is the responsibility of the operator to ensure that any and all health code requirements are being met after setpoint changes.

Operation	Setpoint Value
Critical Temperature (Factory Setting)	20
Berries & Produce	30

Contact Information



Cayuga Displays Inc.
70 Talbot St E
Cayuga, Ontario N0A 1E0

905-772-5214 Option 3
289-921-7575

Email: service@cayugadisplays.com
Website: cayugadisplays.com

Cayuga Displays Inc., whose policy is one of continuous improvement, reserves the right to change at anytime, these specifications, designs or prices without incurring obligation.